



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Model	Product Type	End Connection	Sizes, NPS	Rated Working Pressure	
				psi	kPa
Schedule 10	ASTM A135, ASTM A795	Plain End	1, 1-1/4, 1-1/2, 2	175	1205
		Welded, Rolled Groove	1, 1-1/4, 1-1/2, 2, 2-1/2	300	2065
Schedule 40	ASTM A53, ASTM A135, ASTM A795	Plain End	½, ¾, 1, 1-1/4, 1-1/2, 2	175	1205
		Threaded, Rolled Groove, Cut Groove	½, ¾, 1, 1-1/4, 1-1/2, 2	300	2065

Prepared for:

Fayette Pipe Co
2282 University Drive
Lemont Furnace, PA 15456 United States

FM Approvals Class: 1630 (June 2021) – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: PR466057
PR455165
PR452304

Approval Granted: 3 October 2023
8 January 2021
1 May 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

