

CERTIFICATE OF COMPLIANCE

Certificate Number EX27996
Report Reference EX27996-2019-02-22
Issue Date 2023-SEPTEMBER-27

Issued to: Fayette Pipe Co.
Manufacturer Company: 2282 University Dr.
Lemont Furnace, PA 15456

Listed Company: Specialty Conduit & Mfg. LLC
760 Braddock View Rd.
P.O. Box 259
Mt. Braddock, PA 15465-0259

**This is to certify that
representative samples of** Metallic Sprinkler Pipe
See addendum for model information

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 – Metallic Sprinkler Pipe for Fire-Protection Service
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX27996
Report Reference EX27996-2019-02-22
Issue Date 2023-SEPTEMBER-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Schedule 10, steel sprinkler pipe in the 1, 1-1/4, 1-1/2, 2 and 2-1/2 in.

Schedule 40, steel sprinkler pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, and 2 in. sizes.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

